

ADDENDUM No. 1

This addendum shall be included in, and be considered a part of the Request for Qualification (RFQ) for the above named project. The Contractor shall be required to sign an Acknowledgement of the receipt of this Addendum at the time he receives it. The Acknowledgement must also be submitted with the RFQ Proposal Statement.

Addendum No. 1 - Additional Contractor Questions: (For information only, does not change or modify the RFQ in any manner)

Questions from HONEYWELL

1. Is the integration with the existing Intellisoft IDMS required?

Response: Yes.

2. Would the Honeywell's IDMS solution, that is internal/unified to our Pro-Watch Access Control solution, be an acceptable alternate?

Response: No. GMIA has standardized on the Intellisoft solution for IDMS.

3. In the Scope of Work Item C requires creation of a minimum of 4 reports using Microsoft Reporting Engine - Will these be PACS reports or ICE (IDMS) reports?

Response: For this paragraph, it is in regards to IDMS Reports. There will be a requirement for PACS reports to be developed as well, these will be defined in the final bid documents.

4. Will we have access to the ICE database, or is there an ICE API?

Response: The Contractor will have access to the ICE and PACS databases.

5. "What does integration mean? – How will this integration look (example: bi-directional, Insert, Updates, Deletes, Cardholders, Cards, Clearance Codes etc...)?

Response: integration will consist of a bi-directional link that will transmit cardholder data as well as access levels, at a minimum.

Questions from CJIS GROUP LLC

1. When does the Department want this implemented by?

Response: The preliminary schedule for the project has Bid documents submitted on January 7, 2019, Notice-to-Proceed to the Contractor on March 11, 2019 and construction complete on December 16, 2019. This schedule is preliminary and may be adjusted as final design and bid documents are completed. This schedule is subject to change.

2. What is the estimated cost?

Response: The construction budget for this project is approximately \$4,500,000 which includes an allowance for the IDMS Upgrade. This budget is subject to change.

3. Who is the technical contact?

Response: Faith Group, LLC is the engineering design firm for this project. However, for the purpose of this RFQ, all correspondence should go through MKE Project Manager, Mary Turner.

4. Will the VMS need to be upgraded? What about the IDMS?

Response: The VMS does not need to be upgraded, however as part of the integration between PACS and VMS the VMS will require configuration and/or modification. The Intellisoft ICE IDMS will be upgraded from version 7 to version 8 as part of this project.

Questions from CONVERGINT

1. Can MKE please explain further the 50% Milwaukee Residency requirement?

Response: The Prime needs to spend 50% of their payroll dollars to employees that live in Milwaukee County. Subcontractors are included in the 50%.

2. Does the specific financial information requested in Financial Capacity Documentation count against the 25 page limit for the RFQ Response? Including complete Annual Financial Statements as requested consumes much of the given page limit. (Reference Section M.1 & 2)

Response: the total single-sided page limit is increased to 50 pages. Total page count excludes the Cover Letter and Key Staff Resumes.

3. Can MKE confirm that the schedule & cost control approach is looking for specific tools the Contractor will use, or if it is looking for people/process? (Reference Section J)

Response: provide the process the Contractor uses to maintain schedule and cost for a construction project of this size and complexity.

4. Are there specific PACS for which MKE is requesting 'Top Tier' certification? Is the documentation of such certification counted against the 25 page limit? (Reference Section G.5)

Response: the Contractor will be required to maintain a Top Tier certification for the specific PACS they will be providing for this project. The RFQ is not meant to define or specify the manufacturer of the PACS.

Receipt of **Addendum Number One (1)** is hereby acknowledged for Request for Qualifications for **Physical Access Control System Upgrade Project – GMIA Project #A211-17002**.

THIS ACKNOWLEDGEMENT MUST BE SIGNED AND RETURNED WITH THE RFQ PROPOSAL STATEMENT.

COMPANY NAME: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

DATE: _____

SIGNATURE: _____

PRINT NAME/TITLE _____